



City of Crossett

Project No. 2044



ADDENDUM NO. 1 TO THE CONTRACT DOCUMENTS

CITY OF CROSSETT, CROSSETT, AR

2044 EAST CROSSETT SEWER IMPROVEMENTS, CONTRACT 2

This Addendum No. 1 issued by Crist Engineers, Inc. is hereby made a part of the Contract Documents to the same extent as though it were originally included therein. Please read the following items and acknowledge receipt of this addendum on the proposal form when submitting bids.

1. Conditional Approved Equal

Engineer's acceptance of pre-approved or approved equal submissions will not relieve Contractor from his responsibility for any deviation from the requirements of the Contract Documents unless Contractor has in writing called Engineer's attention to such deviation at the time of submission and Engineer has given written approval to the specific deviation, nor shall any acceptance by Engineer relieve contractor from responsibility for errors or omissions in pre-approved or approved equal submissions.

2. Contract Documents

a. Revision of the Bid Form, page 3.

Bid Item No. 8 Geotextile Separator Fabric, Type 1, Quantities ~~1258~~ 1,313 SY

Bid Item No. 11 Riprap, Type 1, Quantities ~~46~~ 39 TON

Please note at the bottom of page 6 of the Bid Form "Quantities are not guaranteed. Final payment will be based on actual quantities."

3. Plans

- a. Revise Plan Sheet No. C6, upper-right side of sheet.

~~“PERIMETER FENCE CONCRETE MOW STRIP 64 SY OF 4000 PSI ASTM C94
CONCRETE W/ 64 SY OF 6 OZ NONWOVEN GEOTEXTILE SEPARATOR FABRIC
(SINGLE LAYER)”~~

“268 LF OF CHAIN LINKED FENCE
268 LF CONCRETE MOW STRIP
1 – 16’ CHAIN LINKED FENCE GATE”

- b. Revise Plan Sheet No. C12, Detail A, Plug Valve Assembly with Vault, Elevation

“8” MJ FL PLUG VALVE W/ EBAA SERIES 2100 MEGAFLANGE RESTRAINED
FLANGE ADAPTOR”

- c. Revise Plan Sheet No. C12, Detail B, Plug Valve Assembly with Vault, Plan View,
Elevation

“8” MJ FL PLUG VALVE W/ EBAA SERIES 2100 MEGAFLANGE RESTRAINED
FLANGE ADAPTOR”

End of Addendum No. 1

All other provisions of the Plans and Contract Documents shall remain in full force and effect.

Issued by CRIST ENGINEERS, INC.



Brian N. Wintle, PE, PhD, BCEE



Please EMAIL this form to Crist Engineers, Inc. at:

abrown@cristengineers.com; pmann@cristengineers.com; bwintle@cristengineers.com

Please call Brian N. Wintle at 501-664-1552 if you have any questions.

The Bidder shall acknowledge receipt of Addendum No. 1 by return EMAIL.

Bidder shall acknowledge Addendum No. 1 on Section 004100 Bid Form (C-410) Addendum No. 1.

Acknowledged by: _____

Please Print

Please Sign

Organization of Company Name:
