

Crist Engineers, Inc.

1 Executive Center Court
Little Rock, Arkansas 72211
Telephone (501) 664-1552
Fax (501) 664-8579
www.cristengineers.com

**Consulting Engineers**

Matthew D. Dunn
Craig A. Johnson
Brian N. Wintle

ADDENDUM NO. 4

DATE: February 13, 2024

PROJECT: Benton Washington Regional Public Water Authority
Phase 1A – Water Treatment Plant Improvements – High Service Pump Station
Rogers, Arkansas

BID DATE: **February 21, 2024 at 2:00PM**


This Addendum forms a part of the Contract Documents and modifies the original documents provided to Bidders, as noted below. Acknowledge receipt of this Addendum in the space provided in the BID FORM. Failure to do so may subject the Bidder to disqualification.

Item No. 1. Refer to Drawing E6.3 and add the following General Notes:

5. All SEL protective relays shall have IEC61850 protocol.
6. Contractor shall obtain the services of a licensed PE to size and specify conductor from neutral grounding resistor to generator and submit methodology and calculations to owner's engineer for approval. Neutral grounding resistor conductors shall be furnished and installed by contractor as specified and approved. Contractor shall install neutral grounding resistor on generator pad.

END OF ITEMS

All other provisions of the Contract Documents remain unchanged. Acknowledge receipt of this addendum on the Bid Form. Bids must be received at Benton Washington Regional Public Water Authority office, 15531 Woods Lodge Road, Rogers, AR 72756 by 2:00 PM on February 21, 2024.


Josh Moore, PE (Crist Engineers, Inc.)

02/13/2024

Date