



ADDENDUM NO. 1

DATE: January 10, 2024

PROJECT: Water Treatment Plant Filter Rehabilitation
Arkadelphia Water Utility
Arkadelphia, Arkansas

BID DATE: January 11, 2024, 11:00 AM

This Addendum forms a part of the Contract Documents and modifies the original documents provided to Bidders, as noted below. Acknowledge receipt of this Addendum in the space provided in the BID FORM. Failure to do so may subject the Bidder to disqualification.

The Contract Documents for the above Project are hereby amended as follows:

ITEM #1: Contract Documents - Bid Form – Article 6 – Time of Completion

Modify Part 6.01 as follows:

- A. Milestone 1 – Filters 5-&6 **3 & 5** Work; April 30, 2024
- B. Milestone 2 – Filters 3-&4 **4 & 6** Work; June 30, 2024

ITEM #2: Contract Documents - Agreement – Article 4 – Contract Times

Modify Part 4.02 as follows:

- A. Parts of the Work shall be substantially completed on or before the following Milestone(s):
 - 1. Milestone 1 – Filters 5-&6 **3 & 5** Work; April 30, 2024
 - 2. Milestone 2 – Filters 3-&4 **4 & 6** Work; June 30, 2024

ITEM #3: Contract Documents – Notice to Proceed

Modify as follows:

- 1. Milestone 1 – Filters 5-&6 **3 & 5** Work; April 30, 2024
- 2. Milestone 2 – Filters 3-&4 **4 & 6** Work; June 30, 2024

ITEM #4: Specifications – Section 013213 – Scheduling of Work

Modify Part 1.4 as follows:

- B. The Filter rehabilitation work will be conducted in the following sequence.
 - 1. Filters 5-&6 **3 & 5** (simultaneously)
 - 2. Filters 3-&4 **4 & 6** (simultaneously)
- C. Milestones:
 - 1. Milestone 1: All work included with the rehabilitation of filters 5-&6 **3 & 5** must be completed and ready for service, including disinfection and testing.
 - a. April 30, 2024

2. Milestone 2: All work included with the rehabilitation of filters ~~3 & 4~~ **4 & 6** must be completed and ready for service, including disinfection and testing.
 - a. June 30, 2024

ITEM #5: Specifications – Section 466100 – Filtration Equipment

Modify Part 3.4.A as follows:

- A. After all work is completed and before the filter is placed in service, the ~~owner~~ **Contractor** will disinfect the entire filter by chlorination in accordance with ANSI/AWWA C653 Standard.

END OF ITEMS

All other provisions of the Contract Documents remain unchanged. Acknowledge receipt of this Addendum on the BID FORM.

CRIST ENGINEERS, INC.



Matthew D. Dunn, P.E.
President