

Crist Engineers, Inc.

205 Executive Court
Little Rock, Arkansas 72205
Telephone (501) 664-1552
Fax (501) 664-8579
www.cristengineers.com

**Consulting Engineers**

Matthew D. Dunn
Craig A. Johnson
Brian N. Wintle

ADDENDUM NO. 1

DATE: December 12, 2025

PROJECT: Lonoke White Public Water Authority
Pressure Reducing Valve Project
Quitman, Arkansas

BID DATE: December 16, 2025, 2:00 PM

This Addendum forms a part of the Contract Documents and modifies the original documents provided to Bidders, as noted below. Acknowledge receipt of this Addendum in the space provided in the BID FORM. Failure to do so may subject the Bidder to disqualification.

The Contract Documents for the above Project are hereby amended as follows:

ITEM #1: Specifications – 133400 - Prefabricated Pressure Reducing Vault Station

Modify Part 2.42. HYDRAULIC ACTUATED CONTROL VALVES – GENERAL – as follows:

Replace with the following: Refer to Section 409113 - Electronic Pressure Reducing Control Valve.

ITEM #2: Drawings – Sheets 10, 11, 14, 15, 18, 19, 20, 23 & 24

The anchor collars downstream of the Pressure Reducing Valve Stations (at the South end of the line on all drawings) are hereby deleted.

ITEM #3: Clarification – Site Access

The contractor is responsible for any improvements needed for site access during construction. After construction finishes, the OWNER must approve any improvements to stay, or the site must be restored to its original condition.

ITEM #4: Clarification – Bid Schedule

The scope of work and the associated costs from Brown Engineers listed in the Appendix should be included in the Electrical and Instrumentation line items in the Bid Schedule. Disregard the reference to David Liles, General Manager, in the proposals.

END OF ITEMS

All other provisions of the Contract Documents remain unchanged. Acknowledge receipt of this Addendum on the BID FORM.

CRIST ENGINEERS, INC.

Matthew D. Dunn, P.E., President